



Product Service

# CERTIFICATE

No. Z2 14 06 84724 010

**Holder of Certificate:** Zhejiang BLD Solar Technology Co., Ltd.  
Qinggang Technological Ind. Zone  
317606 Yuhuan, Zhejiang  
PEOPLE'S REPUBLIC OF CHINA

**Certification Mark:**



**Product:** Crystalline Silicon Terrestrial Photovoltaic (PV) Modules  
Poly-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

**Test report no.:** 704061342705-01



**Date,** 2014-06-24 (Zhulin Zhang)  
Page 1 of 2

TÜV SÜD Product Service GmbH · Zertifizierstelle · Ridlerstraße 65 · 80339 München · Germany

TUV®



Product Service

# CERTIFICATE

No. Z2 14 06 84724 010

**Model(s):** BLD250-72P, BLD255-72P, BLD260-72P, BLD265-72P, BLD270-72P, BLD275-72P, BLD280-72P, BLD285-72P, BLD290-72P, BLD295-72P, BLD300-72P, BLD305-72P, BLD310-72P, BLD210-60P, BLD215-60P, BLD220-60P, BLD225-60P, BLD230-60P, BLD235-60P, BLD240-60P, BLD245-60P, BLD250-60P, BLD255-60P, BLD260-60P, BLD185-54P, BLD190-54P, BLD195-54P, BLD200-54P, BLD205-54P, BLD210-54P, BLD215-54P, BLD220-54P, BLD225-54P, BLD230-54P, BLD165-48P, BLD170-48P, BLD175-48P, BLD180-48P, BLD185-48P, BLD190-48P, BLD195-48P, BLD200-48P, BLD205-48P, BLD125-36P, BLD130-36P, BLD135-36P, BLD140-36P, BLD145-36P, BLD150-36P, BLD165-36P.

**Parameters:**

Rated Output Power at STC:	250 W, 255 W, 260 W, 265 W, 270 W, 275 W, 280 W, 285 W, 290 W, 295 W, 300 W, 305 W, 310 W, 210 W, 215 W, 220 W, 225 W, 230 W, 235 W, 240 W, 245 W, 250 W, 255 W, 260 W, 185 W, 190 W, 195 W, 200 W, 205 W, 210 W, 215 W, 220 W, 225 W, 230 W, 165 W, 170 W, 175 W, 180 W, 185 W, 190 W, 195 W, 200 W, 205 W, 125 W, 130 W, 135 W, 140 W, 145 W, 150 W, 155 W.
Construction:	Framed, with Junction box, Cable and Connectors.
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute, No. 10 West Kaifa Road, Yangzhou, 225009 Jiangsu, P. R. China.
Application Class:	Class A
Maximum System Voltage:	1000 V DC
Fire Safety Class:	Class C

**Tested according to:** IEC 61215:2005  
EN 61215:2005  
IEC 61730-1:2004  
EN 61730-1:2007  
IEC 61730-2:2004  
EN 61730-2:2007

**Production Facility(ies):** 84724

Page 2 of 2

TÜV SÜD Product Service GmbH · Zertifizierstelle · Ridlerstraße 65 · 80339 München · Germany

TUV®